

VOC Content Test Certificate

Friday November 18th, 2011

Manufacturer: RLA Polymers NZ Ltd (67 Dalgety Dr, Mannkau City, Auckland, NZ 2104)

Sample Description: Roberts 80 Carpet Adhesive

Date Tested: November 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Roberts 80 Carpet Adhesive
Indoor Carpet Adhesive 50 grams per Litre as VOC content per material	116 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV11117