

VOC Content Test Certificate

Monday 12th September 2022

Supplier: OXTEK Solutions Pty Ltd 5 / 17-19 Miles Street Mulgrave VIC 3170

Sample Description: X280 Densi-Proof Reo ProtectTM, Batch No: 04G22

Date Tested: September 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	X280 Densi-Proof Reo ProtectTM Batch No: 04G22
Primers, Sealers and Prep Coats: 65 grams per Litre	1 gram per Litre as VOC content per material
<p><i>We hereby certify the X280 Densi-Proof Reo ProtectTM, Batch No: 04G22 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Dr. Tuan Duong
 PhD, BE (Chem. Eng.)
 Senior Consultant



Travis Hale
 Bsc (Biotechnology)
 Senior Consultant

P22080033