

VOC Content Test Certificate

Tuesday July 21st, 2009

Manufacturer: RLA Polymers Pty Ltd (67 Dalgety Drive, Manukau City Auckland New Zealand 2104)

Sample Description: Polymer 265 carpet adhesive

Date Tested: July 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</p>	<p>Polymer 265</p>
<p>Indoor Carpet Adhesive 50 grams per Litre as VOC content material</p>	<p>46 grams per Litre as VOC content material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0907-16