

VOC Content Test Certificate

Friday April 18th, 2008

Manufacturer: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth Victoria 3137)

Sample Description: Roberts Medi-Seal acrylic floor sealer

Date Tested: April 2008

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC)
Content of Paints and Related Coatings.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Medi-Seal
Interior Sealer 65 grams per Litre as VOC content coating	11 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Medi-Seal
One or two pack performance coating for floors 140 grams per Litre as VOC content coating	11 grams per Litre as VOC content per coating



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0804-13