

VOC Content Test Certificate

Thursday 26th September 2024

Supplier: Uzin Utz South Pacific Ltd (PO Box 426, Whangaparaoa, 0943, New Zealand).

Product name: UZIN NC 164 SP

Date Tested: September 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification New Zealand Green Building Council Green Star Design & As Built V1.1-13.1.1B Green Star Interiors V1.1-12.1.1B	UZIN NC 164 SP
General Purpose Adhesives and Sealants Limit: 50 grams per litre	1 gram per litre as VOC content per material
<i>We hereby certify UZIN NC 164 SP is below the VOC Content limits of chosen category specified by Green Star Interiors, Green Star Design & As Built, New Zealand Green Building Council.</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant