

VOC Content Test Certificate

Thursday, 3rd December 2015

Manufacturer: Oxtek Australia Pty Ltd (3-174 Atlantic Drive, Keysborough, VIC, 3173)


Sample Description: X550 Carpark

Date Tested: December 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	X550 Carpark
Internal Sealer 65 grams per Litre as VOC content per mate	<1 grams per Litre as VOC content per material
Specification Green Building Council of Australia Green Green Star Office Design V3 IEQ-13	X550 Carpark
Internal Sealer 65 grams per Litre as VOC content per material	<1 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV151201